

ADDENDUM #2
for
BID – Exhibit Hall Power Upgrades (Halls A & C)
(5/9/2025)

Questions:

- 1) Please provide the manufacturer of the existing busway.

Answer: Existing bus duct is GE/ABB Spectra Series.